

REPUBLIC OF KENYA



MINISTRY OF DEVOLUTION AND ASAL

State Department of Devolution



## COUNTY GOVERNMENT OF WEST POKOT

### Instrument for Devolution Advice and Support (IDEAS) Programme

**Our Ref:** CGWP/EU/T/003/2020-2021

**Date:** 17<sup>th</sup> November, 2020

**Your Ref:**

**TO: ALL PROSPECTIVE BIDDERS**

Dear Sirs/Madams

**RE: ADDENDUM NO 1 TO THE TENDER NO. CGWP/EU/T/003/2020-2021 FOR PROPOSED SUPPLY AND INSTALLATION OF TWO CHILLERS, FREEZER, DETENTION AND RETENTION COLD ROOM AT NASUKUTA EXPORT SLAUGHTER HOUSE**

Please refer to the above Tender.

Following the pre-bid meeting and site visit held in the County Treasury and the site at Nasukuta on 12<sup>th</sup> November, 2020, upon enquiry from the prospective bidders thereat and at our own initiative we make the following clarifications and amendments to the principal tender document.

**1. RELATIONSHIP WITH THE TENDER DOCUMENT**

Save where expressly amended by the terms of this addendum, the principal tender document shall continue to be in full force and effect. The provisions of this addendum shall be deemed to have been incorporated in and shall be read and construed as part of the Principal Tender Document

**2. TENDER NAME DESCRIPTION**

- The tender name is amended to read; **Proposed Supply, Installation, Testing and Commissioning of Two Chillers, Freezer, Detention and Retention Cold Room at Nasukuta Export Slaughter House.**

HEAD OF SUPPLY CHAIN  
MANAGEMENT

17 NOV 2020

COUNTY GOVERNMENT OF WEST POKOT  
KAREN/NGURIA

### 3. TECHNICAL SPECIFICATIONS

- Include air curtains in the freezers, chillers, detention and retention cold room to conserve energy of the cooling load.
- Allow for hacking of the floor of the freezer, chillers, detention and retention cold rooms before fixing of the insulations.
- Allow for thermal heating elements in the freezer and chillers.
- The doors in the chillers and cold rooms to be double leaf hinged each of dimensions. 1000mm wide by 3000mm high opening outside not sliding as indicated in the bills of quantities.
- The doors to the chillers, freezer and cold room to be installed with limit switches.
- Install temperature reading/recorder for the chiller s/freezer/cold rooms.
- Install condensate pipes from evaporators and floor drains.
- The freezing temperature to be -40°C.

### 4. ELIGIBLE EQUIPMENT/RULE OF ORIGIN

- The evaporator to be supplied and installed under the contract whose value exceeds USD. 100,000 shall have its origin in European Union (EU) countries

### 5. DEADLINE FOR SUBMISSION OF TENDERS

The tender closing date has been extended to **2<sup>nd</sup> December, 2020 at 12:00 Noon at County Treasury Boardroom Ground Floor**. Tenders will be opened immediately thereafter the same day.

All other terms and conditions remain as per the Principal Tender Document.

  
Stephen Kapel

Head of Supply Chain Management Services

